



NOTES:

1. SERVICE LINE STUB MUST EXTEND TO THE PROPERTY LINE. A DISCONNECT CLEANOUT SHALL BE INSTALLED ON THE PUBLIC SIDE AT THE PROPERTY LINE.
2. INTEGRAL WYE FITTINGS ON THE SEWER MAIN ARE TO BE USED FOR THE CONNECTION OF THE SERVICE LINE TO THE SEWER MAIN.
3. THE DEPTH OF THE SEWER LINE AT THE PROPERTY LINE SHALL NOT BE LESS THAN 3.75 FEET, NOR MORE THAN 5 FT AS MEASURED FROM THE TOP OF THE PIPE TO THE SURROUNDING GRADE UNLESS THE DISTANCE TO THE BUILDING REQUIRES GREATER DEPTH.
4. BEDDING FROM 4" BELOW BOTTOM OF THE SERVICE LINE TO 12" OVER THE TOP OF PIPE SHALL BE PER DETAIL SM200.
5. SEWER TRACER WIRE ACCESSIBLE AT R/W AND AT PROPERTY BUILDING CLEANOUT.
6. ELECTRONIC MARKER BALL SHALL BE 4" IN DIAMETER, WASTEWATER STANDARD FREQUENCY AND GREEN IN COLOR. MARKER SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S DIRECTIONS.

